

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7135-1517:101

Page 1 of 1

CATEGORY: Audible Signal Device

LISTEE: Commercial Products Group, 1130 Milepost Dr., Columbus, OH 43228
Contact: Andrew Keller (309) 762-0731

DESIGN: Models ASHP, ASLP, 300D, SPHH, SPHX, ASHH and ASHX audible devices. Suitable for outdoor use. May include the following optional devices: Models PTCK25* and PTCK70* connector cards; Models TC-WL, TC-YP, TC-HL, TC-BL, TC-YW, TC-HN, TC-BP, TC-ST, TC-SW and TC-TW tone cards. Refer to listee's data sheet for detailed product description and operational considerations. Additional information may also be located in UL Hazardous Locations Equipment Directory and UL Fire Protection Equipment Directory.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product designation, electrical rating and UL label.

APPROVAL: Listed as audible devices for use with separately listed compatible control units. May be used with separately listed compatible visual signal devices.

Model ASHH and SPHH are suitable for use in hazardous locations, Class I, Group A, B, C and D, Division 2; Class II, Group F and G, Division 2; and Class III. Model ASHX and SPHX are suitable for use in hazardous locations, Class I, Group B, C and D; Class II, Group E, F and G; and Class III.

If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition is required, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to listee's Installation Instructions Manual for details.

XLF: 7135-0476:124

*Corrected 07-13-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 12, 2002**

Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**